

Certification No. 1152

This is to certify that the metering equipment identified as:

Type: ENLDB2MSV1R0

Mgmt. LDN: SAP = 1, "454E4C44423230373030303735333130" (ENLDB20700075310)

manufactured by:

ENEL d.o.o. Beograd

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT 2.3
- Licensed to: ENEL
- COSEM object definitions file version: Object_defs_v2.0_100723.dat

Test performed	Communication profile	Opening mode	Application context	Date and time	Digital signature of the test report
Test 1	3-layer HDLC	Mode_E	LN	01-Oct-2010	DF421A4AA1F8B45DDB72A6FB4DB73E3F
Test 2	3-layer HDLC	Direct_HDLC	LN	30-Sep-2010	668B3F185323F7B927A0E00478823A27

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: <http://www.dlms.com>.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.



The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.

Date: Geneva, the 18th October 2010



General Secretary