

Certification No. 1112

This is to certify that the metering equipment identified as:

Type: ENLDMGSV2R0

Mgmt. LDN: SAP = 1, "454E4C444D4730373030303734323830" (ENLDMG0700074280)

manufactured by:

ENEL d.o.o. Beograd

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT 2.0
- Licensed to: ENEL
- COSEM object definitions file version: Object_defs_v1.7_CTT2_090409.dat
- Interface classes found but not tested: 10, Schedule

Test performed	Communication profile	Opening mode	Application context	Date and time	Digital signature of the test report
Test 1	3-layer HDLC	Mode_E	LN	2009-06-17	BAB4546788140428096A4A710803DBFC
Test 2	3-layer HDLC	Direct HDLC	LN	2009-06-17	E949C31BA1A9EBB52C13A789ABA89182

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: <http://www.dlms.com>.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.



The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.

Date: Geneva, the 23rd June 2009



Paul Fuchs
 General Secretary