

Certification No. 1187

This is to certify that the metering equipment identified as:

Type: EWGE311

Mgmt. LDN: SAP = 1, "455747453331314D3030303030303031" (EWGE311M00000001)

manufactured by:

EWG d.o.o.

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT 2.4
- Licensed to: EWG_NIS
- COSEM object definitions file version: Object_defs_v2.2_110317.dat

Test performed	Communication profile	Opening mode	Application context	Date and time	Digital signature of the test report
Test 1	3-layer HDLC	Direct HDLC Optical port	LN	30 th July 2011	4E194E27D05CE3CB9C803B631D279F4D
Test 2	3-layer HDLC	Direct HDLC RS 485	LN	30 th July 2011	FA2E79BB5A39D2AA6D80A6E88BB9B114

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: <http://www.dlms.com>.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.



The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.

Date: Geneva, the 2nd August 2011

Paul Fuchs

General Secretary