

Certification No. 1088

This is to certify that the metering equipment identified as:

Type: MET410

Mgmt. LDN: SAP = 1, "4D454C4D455434313031303430453334" (MELMET4101040E34)

manufactured by:

MIKROELEKTRONIKA A.D.

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: CTT 2.0
- Licensed to: MIKROELEKTRONIKA
- COSEM object definitions file version: Object_defs_v1.5_CTT2_071218.dat

Test performed	Communication profile	Physical interface	Application context	Date and time	Digital signature of the test report
Test 1	3-layer HDLC	Optical / Direct HDLC	LN	2008-05-09	A5753123BC07864AC067F91CF8770762
Test 2	3-layer HDLC	RS 232 / Direct HDLC	LN	2008-05-09	85DC3C90041E8D6523A9CF0D619FA6E5

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: <http://www.dlms.com>.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark – shown below – on its product duly identified and on its product literature.



The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested. The test has been executed on one specimen of the product, as identified by the Management Logical Device Name reported. Results may not be applicable for other test specimens.

Date: Geneva, the 10th May 2008

Paul Fuchs

Paul Fuchs
General Secretary