

Certification No. 1057

This is to certify that the metering equipment identified as:

MET400-R1

manufactured by:

Mikroelektronika

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: 1.02.3
- Licensed to: Mikroelektronika A.D.
- COSEM object definitions file version: Object_defs_v1.2_CTT1_070116.dat

Test performed	Communication profile	Physical interface	Application context	Date and time	Digital signature of the test report
Test 1	3-layer HDLC	Optical	LN	16 th April 2007	9D5F3D099DB8FA59769D47041A544A75
Test 2	3-layer HDLC	RS 232	LN	16 th April 2007	FB244EE59AF002F6D5E7838E0A1C6CBD

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: <http://www.dlms.com>.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark - shown below - on its product duly identified and on its product literature.



The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested. The test has been executed on one specimen of the product. Results may not be applicable for other test specimens.

Geneva, the 17th of April 2007



Paul Fuchs
General Secretary