

Certification No. 1063

This is to certify that the metering equipment identified as:

EC9

manufactured by:

Fabryka Aparatury Pomiarowej PAFAL Spolka Akcyjna in cooperation with EMH

has successfully passed the DLMS/COSEM Conformance test, under the following conditions:

- CTT version: 2.0 (Beta 2g)
- Licensed to: EMH Wittenburg
- COSEM object definitions file version: Object_defs_ v1.4_CTT2_070531.dat

Test performed	Communication profile	Physical interface	Application context	Date and time	Digital signature of the test report
Test 1	3-layer HDLC	Optical, Mode E	SN	2007-07-12	E942465952473D90804C81793BADA7C0
Test 2	3-layer HDLC	Current loop	SN	2007-07-12	98AC217345E8C1BD1559B5EC43A88131
Test 3	3-layer HDLC	RS 232	SN	2007-07-12	E1A45239638296E6CD25D0B922681A08
Test 4	3-layer HDLC	RS 485	SN	2007-07-12	DEB46489D005C9C1085818A2FF595D34

The authenticity of the test report(s) has been verified by the DLMS User Association and the metering equipment identified above is listed on its web site at: <http://www.dlms.com>.

With this, the manufacturer is entitled to display the DLMS/COSEM Compliant mark - shown below - on its product duly identified and on its product literature.



The test reports are filed by the DLMS UA. Copies are available from the manufacturer.

This Certificate is only valid for the functions successfully tested. The test has been executed on one specimen of the product. Results may not be applicable for other test specimens.

Date: Geneva, the 13th July 2007



Paul Fuchs
General Secretary